


TECHNICAL SPECIFICATIONS

| Model | Voltage | Power |
|---|---|---|
| S | 115 to 230 V - (switching) +10/-15% 50/60 HZ | 6 VA 50 mA - max. |
| Insulation guaranteed by the power supply | | |
| insulation from very low voltage parts | | reinforced 6 mm in air, 8 on surface 3750 V insulation |
| insulation from relay outputs | | primary 3 mm in air, 4 on surface 1230 V insulation |
| Inputs | | |
| S1 | NTC or PTC depending on the model | |
| S2 | NTC or PTC depending on the model | |
| D1 | free contact, contact resistance < 10 Ω, closing current 6 mA NTC or PTC depending on the model | |
| D2 | free contact, contact resistance < 10 Ω, closing current 6 mA NTC or PTC depending on the model | |
| S4 | Maximum distance of probes and digital inputs less than 10 m | |
| Note: during installation keep the power and loads connection separate from probe cables, digital inputs, repeater display and supervisory system. | | |
| Probe type | | |
| NTC std. CAREL | 10 kΩ at 25 °C | -50/90 °C range measurement error: 1 °C in the -50/50 °C range 3 °C in the -50/90 °C range |
| NTC high temperature | 50 kΩ at 25 °C | -40/150 °C range measurement error: 1.5 °C in the -20/115 °C range 4 °C in the external range at -40/150 °C |
| PTC std. CAREL (specific model) | 985 Ω at 25 °C | -50/150 °C range measurement error: 2 °C in the -50/50 °C range 4 °C in the -50/150 °C range |
| Relay outputs | | |
| depending on the model | | |
| EN60730-1 | | UL 873 |
| 250 V - | | 250 V - |
| 5 A | 5 (1) A | 100000 5 A resistive 1FLA RLRA C300 |
| 8 A | 8 (4) A on N.C. 6 (4) A on N.C. 2 (2) A if the N.C. and N.O. contacts are connected contemporaneously | 100000 8 A resistive 2FLA 12LRA C300 |
| 30 A 12 (2) A on N.O. and N.C. | | 100000 12 A res. 2 Hp 12FLA 30000 |
| insulation from very low voltage parts | | reinforced 6 mm in air, 8 on surface 3750 V insulation |
| Connections | | |
| Type of connection | Cross-sections | Maximum current |
| fixed screw-on removable for screw blocks fasten with crimped contacts | for wires from 0.5 to 2.5 mm ² | 12 A |
| the installer has to provide the correct dimensioning of the power supply and cable connection between the instruments and the loads. Max. current on terminals 5 and 8: 12 A. In max load and max operating temp. conditions, cables rated for operation at up to 105 °C are required. | | |
| Case | | |
| plastic | dimensions 36x167x45 mm mount-in depth 40 mm | |
| panel | using screws from front panel drilling template dimensions 29x138.5 mm | |
| fastening screws | countersunk with tread diameter 3.9 mm maximum | |
| Mounting | | |
| digits | 3 digit LED | |
| display range | from -99 to 999 | |
| operating status | indicated by graphic icons on the display | |
| Keypad | | |
| 8 rubber silicon buttons | | |
| Infrared receiver | | |
| available depending on the models | | |
| Clock with backup battery | | |
| available on all models | | |
| Buzzer | | |
| available on all models | | |
| Clock | | |
| error at 25 °C | ±10 ppm (±5.3 min/year) | |
| error in the temperature range -10/60 °C | -50 ppm (-27 min/year) | |
| ageing | < ±5 ppm (±2.7 min/year) | |
| discharge time | typical 6 months (max. 8 months) | |
| recharge time | typical 5 hours (< 8 hours max.) | |


| | |
|---|---|
| Operating temperature | -10/65 °C |
| Operating humidity | <90% r.H. non-condensing |
| Storage temperature | -20/70 °C |
| Storage humidity | <90% r.H. non-condensing |
| Front panel index of protection | IP65 for panel installation with gasket |
| Environmental pollution | normal |
| PTI of the insulating material | > 250 V |
| Period of electric stress across insulating parts | long |
| Category of resistance to fire | category D (UL 94-V0) |
| Class of protection against voltage surges | category 1 |
| Type of connection and disconnection | 1 C relay contacts (micro-disconnection) |
| Classification according to protection against electric shock | to be integrated in Class I device |
| Software class and structure | class A only use neutral detergents and water |
| Front panel cleaning | only use neutral detergents and water |
| Serial interface for CAREL network | external, available on all models |
| Interface for repeater display | external, available on models with H and O power supply |
| Max. distance between interface and display | 10 m |
| Programming key | available on all models |

Safety standards: compliant with the European reference standards.
 Precautions for installation:
 • the connection cables must guarantee insulation at up to 90 °C;
 • adequately secure the connection cables to the outputs so as to avoid contact with very low voltage components.

Dimensioni / Dimension



Collegamenti elettrici / Electrical wiring:



Option codes

| CODE | DESCRIPTION |
|------------|--|
| RTRES000 | small remote control |
| IROPZDS00 | remote display interface |
| PST00VR100 | remote repeater display |
| PSTCON0B0 | repeater display conn. cables (*: 1.5 m; 3: 3 m; 5: 5 m) |
| IROPZ48S0 | RS485 serial board interface with automatic recognition of the polarity +/- |
| PSOPZKEV00 | parameter programming key with 12 V battery included |
| IROPZKEV00 | parameter programming key with extended memory and 12 V batteries included |
| PSOPZKEVAD | parameter programming key with 230 Vdc power supply |
| IROPZKEVAD | parameter programming key with extended memory and external 230 Vac power supply |
| PSOPZPRG00 | key programming kit |

Display

powercompact small uses a built-in display terminal with three LED digits and icon, to display the operating status. An additional display can be connected to the powercompact small controller, via a suitable interface for example to display the reading of a third probe.

Signals on the display

| Icon | Function | ON | Normal operation | blinking | Startup |
|------------------|---|-----------------------------------|---|--------------------|-------------------------------|
| COMPRESS. | compressor ON | compressor ON | compressor OFF | compressor request | |
| FAN | fan ON | fan OFF | fan request | | |
| DEFROST | defrost ON | defrost OFF | defrost request | | |
| AUX | auxiliary output AUX active | auxiliary output AUX not active | anti-sweat heater function active | | |
| ALARM | delayed external alarm (before the expiry of the time 'A7') | no alarm present | alarms in normal operation (e.g. high/low temperature) or alarm from external digital input, immediate or delayed | | |
| CLOCK | if at least 1 timed defrost has been set | no timed defrost is present | clock alarm | | ON if real-time clock present |
| LIGHT | auxiliary output LIGHT active | auxiliary output LIGHT not active | anti-sweat heater function active | | |
| SERVICE | | no malfunction | malfunction (e.g. EEPROM error or probe fault) | | |
| HACCP | HACCP function enabled | HACCP function not enabled | HACCP alarm (HA and/or HF) | | |
| CONTINUOUS CYCLE | CONTINUOUS CYCLE enabled | CONTINUOUS CYCLE not enabled | CONTINUOUS CYCLE request | | |

The blinking status indicates a request for activation that cannot be implemented until the end of the corresponding delay times.

Buttons on the keypad

| Icon | Button | Normal operation | Startup | Request automatic address assignment |
|----------|--------|--|--|--|
| HACCP | | enters the menu to display and delete the HACCP alarms | | |
| ON/OFF | | if pressed for more than 5 s, switches the unit on/off | | |
| PRG/MUTE | | if pressed for more than 5 s, accesses the menu for setting type "F" (frequent) parameters in the event of alarm; silences the audible alarm (buzzer) and disables the alarm relay | if pressed for more than 5 s together with the SET button, accesses the menu for setting the type "C" (configuration) or downloading the parameters | if pressed for more than 1 s, enters the automatic address assignment procedure for setting the default values |
| UP/CC | | if pressed for more than 5 s, enables/disables continuous cycle operation | if pressed per more than 5 s together with the SET button, starts the procedure for printing the reports (function available, with management to be implemented) | |
| LIGHT | | if pressed for more than 1 s, enables/disables auxiliary output 2 | if pressed for more than 5 s together with the PRG/MUTE button, resets any active alarms with manual reset | |
| AUX | | if pressed for more than 1 s, enables/disables auxiliary output 1 | | |
| DOWN/DEF | | if pressed for more than 5 s, enables/disables a manual defrost | | |
| SET | | if pressed for more than 1 s, displays and/or sets the set point | if pressed for more than 5 s together with the PRG/MUTE button, accesses the menu for setting the type "C" (configuration) or downloading the parameters | |

Setting the set point (desired temperature)

To display or set the set point, proceed as follows:
 1) press the "set" button for more than 1 second to display the set point;
 2) increase or decrease the value of the set point, using the "▲" and "▼" buttons respectively, until reaching the desired value;
 3) press the "set" button again to confirm the new value.

Alarms with manual reset

The alarms with manual reset can be reset by pressing the "PRG" and "▲" buttons together for more than 5 seconds.

Manual defrost

As well as the automatic defrost function, a manual defrost can be enabled, if the temperature conditions allow, by pressing the corresponding button for 5 seconds.

ON/OFF button

Pressing this button for 5 seconds turns the unit on/off. When the controller is turned off, it actually goes into standby, and therefore, when carrying out maintenance on the device, it must be disconnected from the power supply.

HACCP function

powercompact small is compliant with the HACCP standards in force since it allows the monitoring of the temperature of the stored food. "HA" alarm = exceeded maximum threshold; up to three HA events are saved (HA, HA1, HA2) respectively from the more recent (HA) to the oldest (HA2) and a HAn signal that displays the number of occurred HA events. "HF" alarm = power failure lasting over a minute and exceeded AH maximum threshold; up to three HF events are saved (HF, HF1, HF2) respectively from the more recent (HF) to the oldest (HF2) and a HFn signal that displays the number of occurred HF events. HAHF alarm setting: AH parameter (high temperature threshold); Ad and Htd (Ad+Htd = HACCP alarm activation delay).
 Display of the details: access to HA or HF parameters pressing the "set" button and use "▲" or "▼" buttons to glance over.
 HACCP alarm erasing: press the "HACCP" button for more than 5 s, the message "tes" indicates that the alarm has been deleted. To cancel the saved alarms press the "HACCP" and "▲" buttons for more than 5 s.

Continuous cycle

Pressing the button "▲" for more than 5 seconds enables the continuous cycle function. During operation in continuous cycle, the compressor continues to operate for the time "cc" and it stops when reaches the "cc" time out or the minimum temperature envisaged (AL = minimum temperature alarm threshold).
 Continuous cycle setting: "cc" parameter (continuous cycle duration); "cc" = 0 never active; "cc" parameter (bypassing the alarm after the continuous cycle); it avoids or delays the low temperature alarm after the continuous cycle.

Procedure for setting the default parameter values

Procedure for setting the default parameter values
 To set the default parameter values on the controller, proceed as follows:
 • If "Hdn" = 0: 1: switch the instrument off; 2: switch the instrument back on, holding the "PRG" button until the message "Std" is shown on the display.
 Note: the default values are only set for the visible parameters (C and F). For further details see table "Summary of operating parameters".
 • If "Hdn" > 0: 1: switch the instrument off; 2: switch the instrument back on, holding the "PRG" button until the value 0 is shown on the display; 3: select the set of default parameters, between 0 and "Hdn"; using the "▲" and "▼" buttons; 4: press the "PRG" button until the message "Std" is shown on the display

Automatic assignment of the serial address

This is a special procedure that, using an application installed on a PC, allows setting and managing simply the addresses of all instruments (featuring this function) connected to the CAREL network. The procedure is very simple:
 1) Using the remote application. The "Network definition" procedure is started; the application sends a special message (<AdR>) across the CAREL network, containing the network address.
 2) Pressing the "PRG" on an instrument connected to the network recognises the message sent by the remote application, automatically sets the address to the desired value and sends a confirmation message to the application, containing the unit code and firmware revision (message "V"). When the message sent by the remote application is recognised, the instrument shows the message "Add" on the display for 5 seconds, followed by the value of the serial address assigned.
 3) The application, on receiving the confirmation message from the units connected to the network, saves the information received in its database, increases the serial address and sends the message <AdR> again.
 4) At this point, the procedure starting from point 2 can be repeated on another unit connected to the network, until defining all the network addresses.
 Note: once the address has been assigned to an instrument, the operation, for safety reasons, is disabled on the same instrument for 1 minute, preventing a different address from being assigned to the instrument.

Accessing the configuration parameters (type C)

- Press the "PRG" and "set" buttons at the same time for more than 5 seconds; the display will show the number "00" (password prompt).
- Press the "▲" or "▼" button until displaying the number "22" (parameter access password).
- Confirm by pressing the "set" button.
- The display shows the code of the first modifiable "C" parameter.

Accessing the configuration parameters (type F)

- Hold the "PRG" button for more than 5 s (if there are active alarms, first mute the buzzer), the display will show the first modifiable "F" parameter.

Modifying the parameters

- After having displayed the parameter, either type "C" or type "F", proceed as follows:
 1) Press the "▲" or "▼" button to scroll the parameters, until reaching the parameter to be modified. When scrolling, an icon appears on the display representing the category the parameter belongs to.
 2) Alternatively, press the "PRG" button to display a menu that is used to quickly access the family of parameters to be modified.
 81) F2: Fan OFF with compressor OFF
 82) F3: Fans in defrost
 83) Fd: Fans off after dripping
 84) F4: Condenser fan OFF temperature
 85) F5: Condenser fan ON differential
 86) H0: Serial address
 87) H1: Function of aux 1
 88) H2: Disable keypad/Infrared
 89) H3: Remote control enabling code
 90) H4: Disable buzzer
 91) H5: Function of aux 2
 92) H6: Lockout buttons
 93) H8: Select output to activate with time band
 94) H9: Enable set point variation with time band
 95) Hdh: Anti-sweat heater offset
 96) HAn: Number of HA events occurred
 97-99) HA-1-2: Date/Time of the last/second-last/third-last HA event
 y: Year
 M: Month
 d: Day
 h: Hour
 n: Minute
 t: Duration
 100) HFn: Number of HF events occurred
 101-103) HF-1-2: Date/Time of the last/second-last/third-last HF event
 y: Year
 M: Month
 d: Day
 h: Hour
 n: Minute
 t: Duration
 104) Htd: HACCP alarm delay
 105...112) t01...t08: Defrost time band 1-2-3-4-5-6-7-8
 d: Day
 h: Hour
 n: Minute
 113...114) ton-tof: Light/aux ON/OFF time band
 d: Day
 h: Hour
 n: Minute
 115) tc: RTC date/time setting
 y: Year
 M: Month
 d: Day of the month
 u: Day of the week
 h: Hour
 n: Minute

Saving the new values assigned to the parameters

To definitively save the new values of the modified parameters, press the "PRG" button for more than 5 seconds, thus exiting the parameter setting procedure.
 All the modifications made to the parameters, temporarily saved in the RAM, can be cancelled and "normal operation" resumed by not pressing any button for 60 seconds, thus allowing the parameter setting session to expire due to timeout.
 If the instrument is switched off before pressing the "PRG" button, all the modifications made to the parameters and temporarily saved will be lost.

Directly accessing the parameters by selecting the category

The configuration parameters can also be accessed, in addition to the mode described above, via the category (see the icons and abbreviations in the table below), according to the list on the display with the corresponding name and icon.
 To directly access the list of parameters grouped by category, press the "PRG" button for at least 1 second, "▲" or "▼" and to modify the parameter press "set", "▲" or "▼".

| Category | Parameters | Message | Icon |
|--------------------------|-----------------|---------|------|
| Probe parameters | / | 'Pro' | |
| Control parameters | r | 'Cil' | |
| Compressor parameters | c | 'CMP' | |
| Defrost parameters | d | 'dEF' | |
| Alarm parameters | A | 'ALM' | |
| Fan parameters | F | 'Fan' | |
| Configuration parameters | H configuration | 'CnF' | |
| HACCP parameters | H HACCP | 'HcP' | |
| RTC parameters | rtc | 'rtc' | |

Probe configuration (A2...A4)

In the powercompact small series, these parameters are used to configure the operating mode of the probes:
 0 = probe absent; 1 = product probe (used for display only); 2 = defrost probe; 3 = condenser probe; 4 = antifreeze probe.

Configuration of the digital inputs (A4, A5)

In the powercompact small series, this parameter and the model of controller used define the meaning of the digital input:
 0 = input not active;
 1 = immediate external alarm, normally closed; open = alarm;
 2 = delayed external alarm, normally closed;
 3 = enable defrost from external contact: open = disabled (an external contact can be connected to the multifunction input to enable or disable the defrost);
 4 = start defrost from external contact;
 5 = door switch with stopping of compressor and fans: open = open door
 6 = remote ON/OFF: CLOSED=ON;
 7 = curtain switch: close = lowered curtain;
 8 = low pressure switch input for pump-down: open = low pressure;
 9 = door switch with stopping of fans only: open = open door;
 10 = direct/reverse cycle operation: open = direct;
 11 = light sensor;
 12 = AUX output enabling (if configured with H1 or H5 parameters): opening = enabling;
 13 = door switch with compress and fans OFF with light not managed;
 14 = door switch with fans OFF and light not managed

Configuration of the relay outputs AUX1 and AUX2 (H1/H5)

Establishes whether the fourth and fifth relays (present only if envisaged by the model) are used as auxiliary outputs (e.g. demister fan or other ON/OFF actuator), an alarm output, a light output, a defrost actuator for the auxiliary evaporator, pump-down valve control or output for the condenser fan.
 0 = alarm output: normally energised; the relay is de-energised when an alarm occurs;
 1 = alarm output: normally de-energised; the relay is energised when an alarm occurs;
 2 = auxiliary output;
 3 = light output;
 4 = auxiliary evaporator defrost output;
 5 = pump-down valve output;
 6 = condenser fan output;
 7 = delayed compressor output;
 8 = auxiliary output with OFF shutdown;
 9 = light output with OFF shutdown;
 10 = disabled output;
 11 = reverse output in dead zone control;
 12 = second compressor step output;
 13 = second compressor step output with rotation.

Warning: the mode H1/H5=0 is useful for signalling the alarm status even in case of power failure.
 Note: in the models fitted with only one auxiliary output, to associate the button "▲" to this output, set H1 = 0 and H5 = 0. It is necessary to associate the relay assigned to aux 1 to the auxiliary output 2. The operation can be performed using the programming kit PSOPZPRG00 and the programming key PSOPZKEV00A.

Date and day for defrost event (parameters t01...t08)

0 = no event; 1..7= Monday..Sunday; 8= from Monday to Friday; 9= from Monday to Saturday; 10= from Saturday to Sunday; 1= every day.

Summary of operating parameters

| No. | Code | Parameter | Model | UOM | Type | Def. | Max. | Min. |
|---------|-----------|---|-------|---------|------|------|------|------|
| 1 | /2 | Password | MSYF | - | C | 22 | 200 | 0 |
| 2 | /3 | Measurement stability | MSYF | - | C | 4 | 15 | 1 |
| 3 | /3 | Probe display reaction | MSYF | - | C | 0 | 15 | 0 |
| 4 | /4 | Virtual probe | MSYF | - | C | 0 | 100 | 0 |
| 5 | /4 | Select "C" or "F" | MSYF | flag | C | 0 | 1 | 0 |
| 6 | /6 | Decimal point | MSYF | flag | C | 0 | 1 | 0 |
| 7 | /6 | Display on internal terminal | MSYF | - | C | 1 | 7 | 1 |
| 8 | /6 | Display on external terminal | MSYF | - | C | 0 | 6 | 0 |
| 9 | /P | Select type of probe | MSYF | - | C | 0 | 2 | 0 |
| 9 | /A2 | Configuration of probe 2 | -S- | - | C | 0 | 3 | 0 |
| 10...11 | /A3-4 | Configuration of probe 3-4 | MSYF | - | C | 0 | 3 | 0 |
| 12...15 | /c1-2-3-4 | Calibration of probe 1-2-3-4 | MSYF | "C"/"F" | C | 0.0 | 20 | -20 |
| 16 | St | Temperature set point | MSYF | "C"/"F" | C | 0.0 | 12 | 11 |
| 17 | rd | Controller diff. | -SYF | "C"/"F" | F | 2.0 | 20 | 0.1 |
| 18 | rd | Dead zone | -SYF | "C"/"F" | C | 4.0 | 60 | 0.0 |
| 19 | rr | Reverse control delta with dead zone | -SYF | "C"/"F" | C | 2.0 | 20 | 0.1 |
| 20 | r1 | Minimum SET allowed | -SYF | "C"/"F" | C | -50 | -2 | -50 |
| 21 | r2 | Maximum SET allowed | -SYF | "C"/"F" | C | 60 | 200 | 17 |
| 22 | r3 | Compressor mode | -SYF | flag | C | 0 | 1 | 0 |
| 23 | r4 | Automatic night-time set point variation | -SYF | "C"/"F" | C | 3.0 | 20 | -20 |
| 24 | r5 | Enable temperature monitoring | MSYF | flag | C | 0 | 1 | 0 |
| 25 | r1 | Temperature monitoring interval | MSYF | hours | F | - | 999 | 0 |
| 26 | rH | Maximum temperature read | MSYF | "C"/"F" | F | - | - | - |
| 27 | rL | Minimum temperature read | MSYF | "C"/"F" | F | - | - | - |
| 28 | c0 | Start delay for compressors, fans and AUX on power-up, in dead zone control | -SYF | min | C | 0 | 15 | 0 |
| 29 | c1 | Minimum time between successive starts | -SYF | min | C | 0 | 15 | 0 |
| 30 | c2 | Minimum compressor OFF time | -SYF | min | C | 0 | 15 | 0 |
| 31 | c3 | Minimum compressor ON time | -SYF | min | C | 0 | 15 | 0 |
| 32 | c4 | Duty setting | -SYF | min | C | 0 | 100 | 0 |
| 33 | cc | Continuous cycle duration | -SYF | hours | C | 0 | 15 | |